



HEINLEIN SUPPLY CO.

Heating, Ventilating, Air Conditioning Equipment
5516 N ELSTON AVE CHICAGO, IL 60630-1379 PH#:773-774-8616 FX#:773-774-8622

ILG McDonalds Fan - Common Replacement Parts

NUMBER	PART #	DESCRIPTION	QTY	PRICE	TOTAL
3	8500-4798	GROMMET • 4 ON EACH UNIT			
6/6A	2113-9312A	WHEEL/BUSHING FOR MCD 135/R			
6/6A	2116-9307A	WHEEL/BUSHING FOR MCD 165/R			
8	2113-9062A	SHAFT/BEARING KIT FOR MCD 135/R			
8	2116-9075A	SHAFT/BEARING KIT FOR MCD 165/R			
13	2113-1112A	SWIVEL BRACKET			
14	2113-1114A	MOTOR PLATE			
16	1500B-0001	FAN BELT TENSION KIT ➤ KEEPS PROPER TENSION ON FAN BELT			
18	83-20-211R	½ HP MOTOR 115V, 1PH, 60 HZ FOR MCD 135/R			
18	84-20-211R	¾ HP MOTOR 115V, 1PH, 60 HZ FOR MCD 165/R			
19	8500-4805	AIR HOSE ➤ PROVIDES COOL OUTSIDE AIR DIRECTLY TO MOTOR			
22		MOTOR SHEAVES • <i>REQUIRES SHEAVE # OR DIMENSIONS, DIAMETER & BORE SIZE</i>			
22A		FAN SHEAVES • <i>REQUIRES SHEAVE # OR DIMENSIONS, DIAMETER & BORE SIZE</i>			
22B		BELT • <i>REQUIRES BELT # OR LENGTH OF CIRCUMFERENCE</i>			
25A	8500-4808	ORANGE GASKET ➤ SEALS MOTOR COMPARTMENT FROM HEAT & GREASE • MCD 135/R REQUIRES 2 STRIPS PER DOME • MCD 165/R REQUIRES 3 STRIPS PER DOME			
25C	2113-0001	WINGNUT, RUBBER & ALUMINUM WASHER • SET OF TWO EACH			
26A	8500-4810	GREY DUCT ADAPTER GASKET ➤ SEALS FAN INLET TO EXHAUST DUCT ➤ APPLIED WITH #5900-0074 GLUE/CAULK • (1) ROLL GOOD FOR: (2) MCD165 OR (1) MCD165 + (2) MCD135			
25B/26B	5900-0074	GLUE/CAULK ➤ TO APPLY GASKET MATERIAL • 1 TUBE REQUIRED FOR 2 UNITS			
31	8500-4084	SEALTITE CONDUIT ➤ ENCLOSURES WIRES FROM FAN BASE TO FAN			
38	2116-9027H	GREASE TROUGH			